



June 03, 2019

Brent Cosgrove
Godley Public Water District
400 South Center St., PO Box 130
Godley, IL 60407

RE: IL1970130

Dear Brent Cosgrove:

Please find enclosed the analytical results for the **2** sample(s) the laboratory received on **5/23/19 3:30 pm** and logged in under work order **9055052**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Director of Client Services, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lgrant@pdclab.com.

Sincerely,

Project Manager
(309) 692-9688 x1743
jclutters@pdclab.com





ANALYTICAL RESULTS

Sample: 9055052-01
Name: TP01 - VS - WELL 4
Alias: GODLEY
Reg ID: NON-COMPLIANCE

Sampled: 05/22/19 11:04
Received: 05/23/19 15:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Herbicides - PIA							
2,4-D	< 1.0	ug/L		05/29/19 08:21	05/30/19 22:53	JMT	EPA 515.3
Dalapon	< 5.0	ug/L		05/29/19 08:21	05/30/19 22:53	JMT	EPA 515.3
Dicamba	< 0.30	ug/L		05/29/19 08:21	05/30/19 22:53	JMT	EPA 515.3
Dinoseb	< 1.0	ug/L		05/29/19 08:21	05/30/19 22:53	JMT	EPA 515.3
Diquat	< 2.0	ug/L		05/28/19 11:46	05/29/19 12:06	DEM	EPA 549.2
Pentachlorophenol	< 0.40	ug/L		05/29/19 08:21	05/30/19 22:53	JMT	EPA 515.3
Picloram	< 1.0	ug/L		05/29/19 08:21	05/30/19 22:53	JMT	EPA 515.3
Silvex	< 1.0	ug/L		05/29/19 08:21	05/30/19 22:53	JMT	EPA 515.3
Pesticides - PIA							
3-Hydroxycarbofuran	< 1.0	ug/L		05/28/19 08:39	05/28/19 14:26	DEM	EPA 531.1
Carbaryl	< 2.0	ug/L		05/28/19 08:39	05/28/19 14:26	DEM	EPA 531.1
Carbofuran	< 0.9	ug/L		05/28/19 08:39	05/28/19 14:26	DEM	EPA 531.1
Methomyl	< 0.5	ug/L		05/28/19 08:39	05/28/19 14:26	DEM	EPA 531.1
Oxamyl	< 2.0	ug/L		05/28/19 08:39	05/28/19 14:26	DEM	EPA 531.1
Polynuclear Aromatic Hydrocarbons - PIA							
Benzo(a)pyrene	< 0.10	ug/L		05/28/19 11:50	05/29/19 12:44	DEM	EPA 550
Semivolatile Organics - PIA							
4,4'-DDT	< 1.0	ug/L		05/29/19 07:37	05/29/19 14:23	PSB	EPA 525.2
Alachlor	< 0.20	ug/L		05/29/19 07:37	05/29/19 14:23	PSB	EPA 525.2
Aldrin	< 0.050	ug/L		05/29/19 07:37	05/29/19 14:23	PSB	EPA 525.2
Aroclors - Total	< 0.10	ug/L		05/29/19 07:37	05/29/19 14:23	PSB	EPA 525.2
Atrazine	< 0.30	ug/L		05/29/19 07:37	05/29/19 14:23	PSB	EPA 525.2
Bis(2-ethylhexyl) adipate	< 0.60	ug/L		05/29/19 07:37	05/29/19 14:23	PSB	EPA 525.2
Bis(2-ethylhexyl) phthalate	< 1.8	ug/L		05/29/19 07:37	05/29/19 14:23	PSB	EPA 525.2
Chlordane (technical)	< 0.20	ug/L		05/29/19 07:37	05/29/19 14:23	PSB	EPA 525.2
DBCP	< 0.020	ug/L		05/29/19 12:13	05/29/19 21:24	ELS	EPA 504.1
Dieldrin	< 0.050	ug/L		05/29/19 07:37	05/29/19 14:23	PSB	EPA 525.2
EDB	< 0.010	ug/L		05/29/19 12:13	05/29/19 21:24	ELS	EPA 504.1
Endothall	< 9.0	ug/L		05/28/19 09:06	05/28/19 16:03	CRS	EPA 548.1
Endrin	< 0.10	ug/L		05/29/19 07:37	05/29/19 14:23	PSB	EPA 525.2
gamma-BHC (Lindane)	< 0.10	ug/L		05/29/19 07:37	05/29/19 14:23	PSB	EPA 525.2
Heptachlor	< 0.040	ug/L		05/29/19 07:37	05/29/19 14:23	PSB	EPA 525.2
Heptachlor epoxide	< 0.020	ug/L		05/29/19 07:37	05/29/19 14:23	PSB	EPA 525.2
Hexachlorobenzene	< 0.10	ug/L		05/29/19 07:37	05/29/19 14:23	PSB	EPA 525.2
Hexachlorocyclopentadiene	< 0.50	ug/L		05/29/19 07:37	05/29/19 14:23	PSB	EPA 525.2
Methoxychlor	< 0.10	ug/L		05/29/19 07:37	05/29/19 14:23	PSB	EPA 525.2



ANALYTICAL RESULTS

Sample: 9055052-01
Name: TP01 - VS - WELL 4
Alias: GODLEY
Reg ID: NON-COMPLIANCE

Sampled: 05/22/19 11:04
Received: 05/23/19 15:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Propachlor	< 0.50	ug/L		05/29/19 07:37	05/29/19 14:23	PSB	EPA 525.2
Simazine	< 0.35	ug/L		05/29/19 07:37	05/29/19 14:23	PSB	EPA 525.2
Toxaphene	< 1.0	ug/L		05/29/19 07:37	05/29/19 14:23	PSB	EPA 525.2
<u>Volatile Organics - PIA</u>							
1,1,1-Trichloroethane	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
1,1,2-Trichloroethane	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
1,1-Dichloroethene	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
1,2,4-Trichlorobenzene	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
1,2-Dichlorobenzene	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
1,2-Dichloroethane	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
1,2-Dichloropropane	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
1,4-Dichlorobenzene	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
Benzene	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
Carbon tetrachloride	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
Chlorobenzene	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
cis-1,2-Dichloroethene	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
Ethylbenzene	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
Methylene chloride	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
MTBE	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
Styrene	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
Tetrachloroethene	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
Toluene	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
trans-1,2-Dichloroethene	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
Trichloroethene	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
Vinyl chloride	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2
Xylenes- Total	< 0.50	ug/L		05/30/19 09:20	05/30/19 12:27	RSC	EPA 524.2



NOTES

Specific method revisions used for analysis are available upon request.

Certifications

CHI - McHenry, IL

TNI Accreditation for Drinking Water, Wastewater, Fields of Testing through IL EPA Lab No. 100279
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553
Drinking Water Certifications: Iowa (240); Kansas (E-10338); Missouri (870)
Wastewater Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)
Hazardous/Solid Waste Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPIL - Springfield, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Waste Fields of Testing through IL EPA Lab No. 100323

SPMO - Springfield, MO

USEPA DMR-QA Program

STL - St. Louis, MO

TNI Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS Lab No. E-10389
TNI Accreditation for Wastewater, Hazardous, and Solid Waste Analysis through IL EPA No. 200080
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171050
Missouri Department of Natural Resources
Microbiological Laboratory Service for Drinking Water

* Not a TNI accredited analyte

Certified by: Janet Clutters, Project Manager



