



Annual Drinking Water Quality Report for Calendar Year 2021

Godley Public Water District

IL1970130

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. This report includes drinking water facts, information on violations (if applicable), and contaminants detected in your drinking water supply during calendar year 2021. Each year, we will provide you a new report. This report is published in the Braidwood Journal newspaper, posted on the district website, and posted several places locally but will not be direct mailed to individual customers. If you need help understanding this report or have general questions, please contact the persons listed below.

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Contact Name: Joe or Brent Cosgrove
Telephone Number: 815-585-GPWD (4793)
E-mail (if available) Questions@godleypublicwater.org

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Our source of water comes from Ground Water, Well #3 (01406) and Well #4 (01854), in the NE corner of the Godley Park

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

Other Facts about Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Source Water Assessments

Source Water Protection (SWP) is a proactive approach to protecting our critical sources of public water supply and assuring that the best source of water is being utilized to serve the public. It involves implementation of pollution prevention practices to protect the water quality in a watershed or wellhead protection area serving a public water supply. Along with treatment, it establishes a multi-barrier approach to assuring clean and safe drinking water to the citizens of Illinois. The Illinois EPA has implemented a Source Water Assessment Program (SWAP) to assist with wellhead and watershed protection of public drinking water supplies.

Source of Water: GODLEY PUBLIC WATER DISTRICT The source water assessment for this system has not yet been completed by the Illinois EPA. EPA is required to complete source water assessments for all public water supplies, when this assessment becomes available, we will summarize the results and incorporate the information into this report. IEPA has established that a source water assessment shall be completed prior to July 26, 2024.

2021 Regulated Contaminants Detected

The tables below summarize contaminants detected in your drinking water supply.

Here are a few definitions and scientific terms which will help you understand the information in the contaminant detection tables.

| | |
|-------|--|
| AL | Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. |
| Avg | Regulatory compliance with some MCL's is based on running annual average of monthly samples. |
| MCL | Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the Maximum Contaminant Level Goal as feasible using the best available treatment technology. |
| MCLG | Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. |
| MRDL | Maximum Residual Disinfectant Level: The highest level of disinfectant allowed in drinking water. |
| MRDLG | Maximum Residual Disinfectant Level Goal: The level of disinfectant in drinking water below which there is no known or expected risk to health. MRDLG's allow for a margin of safety. |
| N/A | Not Applicable |
| NTU | Nephelometric Turbidity Units |
| pCi/L | picocuries per liter (a measure of radioactivity) |
| ppb | Parts per billion or micrograms per liter (ug/L) - or one ounce in 7,350,000 gallons of water. |
| ppm | Parts per million or milligrams per liter (mg/L) - or one ounce in 7,350 gallons of water. |
| TT | Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water. |

| Lead and Copper | | | | | | | | |
|-----------------|--------------|------|-------------------|-----------------------------|-----------------|-------|-----------|--|
| | Date Sampled | MCLG | Action Level (AL) | 90 th Percentile | # Sites Over AL | Units | Violation | Likely Source of Contamination |
| Copper | 2021 | 1.3 | 1.3 | 0.97 | 0 | ppm | N | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| Lead | 2021 | 0 | 15 | 1.28 | 0 | ppb | N | Corrosion of household plumbing systems; erosion of natural deposits. |

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Godley Public Water District is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

| Disinfectants & Disinfection Byproducts | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation | Likely Source of Contamination |
|---|-----------------|------------------------|--------------------------|---------|--------|-------|-----------|--|
| Chlorine | 2021 | 1.4 | 1.06 – 1.76 | MRDGL=4 | MRDL=4 | ppm | N | Water additive used to control microbes. |
| Haloacetic Acids (HAA5) | 7/27/2021 | 0.985 | 0.985 – 0.985 | No goal | 60 | ppb | N | By-product of drinking water disinfection. |

| Inorganic Contaminants | | | | | | | | |
|--------------------------------|-----------|--------|-----------------|-----|-----|-----|---|--|
| Arsenic | 2/18/2021 | 0.745 | 0.745 – 0.745 | 0 | 10 | ppm | N | Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes. |
| Barium | 2/15/2018 | 0.008 | 0.008 - 0.008 | 2 | 2 | ppm | N | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits. |
| Chromium | 2/18/2021 | 6.72 | 6.72 – 6.72 | 100 | 100 | ppb | N | Discharge from steel and pulp mills; Erosion of natural deposits. |
| Fluoride | 2/18/2021 | 0.986 | 0.986 – 0.986 | 4 | 4.0 | ppm | N | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories. |
| Iron | 2/15/2018 | 0.007 | 0.007 – 0.007 | | 1.0 | ppm | N | This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits. |
| Manganese | 2/18/2021 | 2.68 | 2.68 – 2.68 | 150 | 150 | ppb | N | This contaminant is not currently regulated by the USEPA. However, the state regulates erosion of natural deposits. |
| Nitrate (measured as Nitrogen) | 2/18/2021 | 0.171 | 0.171 – 0.171 | 10 | 10 | ppm | N | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |
| Nitrite (measured as Nitrogen) | 2/18/2021 | 0.054 | 0.054 – 0.054 | 1 | 1 | ppm | N | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |
| Sodium | 2/15/2018 | 195 | 195 – 195 | | | ppm | N | Erosion from naturally occurring deposits: Used in water softener regeneration. |
| Zinc | 2/15/2018 | 0.0571 | 0.0571 – 0.0571 | 5 | 5 | ppm | N | This contaminant is not currently regulated by the USEPA. However, the state regulates. Naturally occurring; discharge from metal. |

| Radiological Contaminants | | | | | | | | |
|---|-----------|-----|-----|---|----|-------|---|------------------------------|
| Combined Radium 226/228 | 5/19/2021 | < 1 | < 1 | 0 | 5 | pCi/L | N | Erosion of natural deposits. |
| Gross alpha excluding radon and uranium | 5/19/2021 | < 3 | < 3 | 0 | 15 | pCi/L | N | Erosion of natural deposits. |

Note: The state requires monitoring of certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Therefore, some of this data may be more than one year old.

Violation Summary Table

We are happy to announce that no monitoring, reporting, treatment technique, maximum residual disinfectant level, or maximum contaminant level violations were recorded during 2021.

CCR Distribution

This report is published in the Braidwood Journal newspaper, posted on the district's website, and posted several places locally but will not be direct mailed to individual customers.